

令和2年度 3月分 毎日水質検査集計表

(単位mg/l)

日	曜日	水温					残留塩素					市内残留塩素					NaClO		pH値					色度					濁度																			
		大阪水		高地区系	配水B	配水塔	高圧	大阪水		処理水			高地区系	配水B	配水塔	高圧	取石分岐	泉北土生	千代田	羽衣	東羽衣	綾園	取石	高砂3	6.0%	大阪水		取石分岐	高地区系	配水B	配水塔	高圧	泉北土生	大阪水		高地区系	配水B	配水塔	高圧	大阪水		高地区系	配水B	配水塔	高圧			
		綾井	北					綾井	北	綾南	綾東	北														綾井	北							綾井	北					綾井	北					綾井	北	綾井
1	月	10.0	10.9	9.9	10.0	10.4	0.63	0.63				0.68	0.63	0.52		0.56	0.67	0.6	0.5	0.5	0.5	0.6	0.3		7.02	7.03		7.18	7.08	7.03		7.35	0.3	0.2	0.6	0.2	0.2		0.00	0.00	0.00	0.00	0.00					
2	火	10.0	10.0	9.3	9.2	10.2	0.61	0.62				0.64	0.58	0.50		0.56	0.66	0.6	0.5	0.5	0.6	0.6	0.3		7.05	7.05		7.15	7.06	7.04		7.35	0.3	0.3	0.7	0.3	0.4		0.00	0.00	0.00	0.00	0.00					
3	水	10.0	10.4	10.2	10.0	10.0	0.60	0.62				0.65	0.59	0.50		0.63	0.66	0.6	0.5	0.5	0.6	0.6	0.3		7.00	7.02		7.17	7.01	7.02		7.31	0.3	0.3	0.6	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
4	木	9.8	10.7	10.0	9.8	9.5	0.61	0.62				0.67	0.60	0.51		0.63	0.65	0.6	0.5	0.5	0.5	0.6	0.3		7.02	7.01		7.18	7.04	7.06		7.30	0.3	0.3	0.9	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
5	金	10.0	---	10.0	10.5	10.5	0.65	---				0.67	0.63	0.54		0.69	0.66	0.6	0.6	0.5	0.6	0.6	0.3		7.01	---		7.19	7.06	7.04		7.32	0.3	---	0.5	0.5	0.4		0.00	---	0.00	0.00	0.00					
6	土	10.2	---	10.1	10.0	10.6	0.60	---				0.72	0.61	0.53		0.63	0.69	0.6	0.5	0.5	0.6	0.6	0.3		7.02	---		7.25	7.03	7.03		7.29	0.3	---	0.7	0.2	0.4		0.00	---	0.00	0.00	0.00					
7	日	10.8	---	10.8	10.6	10.6	0.60	---				0.69	0.59	0.50		0.63	0.68	0.5	0.5	0.5	0.5	0.6	0.3		7.02	---		7.18	7.05	7.06		7.26	0.2	---	0.7	0.2	0.3		0.00	---	0.00	0.00	0.00					
8	月	10.1	---	10.1	10.1	9.9	0.61	---				0.67	0.61	0.53		0.63	0.66	0.5	0.5	0.5	0.6	0.6	0.3		7.02	---		7.17	7.03	7.02		7.27	0.2	---	0.7	0.2	0.3		0.00	---	0.00	0.00	0.00					
9	火	10.0	---	10.2	10.2	9.0	0.61	---				0.67	0.60	0.52		0.64	0.65	0.6	0.5	0.5	0.6	0.6	0.3		7.00	---		7.17	7.00	7.02		7.27	0.2	---	0.6	0.3	0.3		0.00	---	0.00	0.00	0.00					
10	水	10.8	---	10.8	11.0	10.5	0.60	---				0.70	0.58	0.50		0.62	0.70	0.6	0.6	0.5	0.6	0.6	0.3		7.02	---		7.19	7.04	7.05		7.28	0.2	---	0.7	0.3	0.3		0.00	---	0.00	0.00	0.00					
11	木	11.0	11.4	11.2	11.2	11.0	0.57	0.59				0.65	0.59	0.50		0.63	0.63	0.5	0.6	0.5	0.6	0.6	0.3		7.01	7.02		7.20	7.03	7.03		7.28	0.3	0.3	0.7	0.3	0.5		0.00	0.00	0.00	0.00	0.00					
12	金	11.5	11.5	11.0	11.0	11.0	0.63	0.63				0.66	0.60	0.53		0.62	0.65	0.6	0.6	0.5	0.6	0.6	0.3		7.01	7.01		7.19	7.04	7.03		7.28	0.3	0.4	0.6	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
13	土	11.1	11.2	11.0	10.9	11.0	0.61	0.61				0.68	0.59	0.51		0.63	0.69	0.4	0.5	0.5	0.6	0.6	0.3		7.04	7.04		7.23	7.04	7.05		7.31	0.4	0.4	0.6	0.4	0.4		0.00	0.00	0.00	0.00	0.00					
14	日	11.2	11.8	10.9	11.1	11.0	0.61	0.61				0.65	0.60	0.51		0.62	0.68	0.5	0.6	0.5	0.5	0.6	0.3		7.04	7.04		7.16	7.03	7.05		7.27	0.3	0.3	0.5	0.4	0.4		0.00	0.00	0.00	0.00	0.00					
15	月	12.0	12.0	11.5	11.5	11.5	0.63	0.63				0.66	0.60	0.52		0.62	0.66	0.6	0.6	0.5	0.5	0.6	0.3		7.01	7.01		7.21	7.05	7.03		7.28	0.4	0.3	0.6	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
16	火	11.8	12.4	11.6	11.6	11.8	0.62	0.62				0.68	0.63	0.52		0.65	0.63	0.6	0.6	0.5	0.6	0.6	0.3		7.02	7.03		7.19	7.08	7.02		7.29	0.3	0.3	0.5	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
17	水	11.2	12.0	11.2	11.2	11.9	0.60	0.60				0.66	0.58	0.52		0.62	0.63	0.5	0.6	0.5	0.6	0.6	0.3		7.04	7.02		7.15	7.05	7.03		7.29	0.3	0.3	0.5	0.5	0.3		0.00	0.00	0.00	0.03	0.00					
18	木	11.3	11.9	11.7	11.7	11.2	0.61	0.61				0.67	0.59	0.51		0.62	0.64	0.6	0.5	0.5	0.5	0.6	0.3		7.05	7.05		7.19	7.04	7.06		7.25	0.2	0.3	0.5	0.3	0.4		0.00	0.00	0.00	0.00	0.00					
19	金	12.0	12.0	12.2	12.0	12.0	0.63	0.61				0.68	0.57	0.51		0.62	0.67	0.6	0.6	0.5	0.5	0.6	0.3		7.00	7.02		7.14	7.06	7.02		7.26	0.3	0.3	0.4	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
20	土	13.0	13.2	12.7	12.6	13.0	0.60	0.61				0.65	0.56	0.51		0.62	0.64	0.5	0.6	0.5	0.5	0.6	0.3		7.00	7.01		7.18	7.02	7.03		7.27	0.3	0.3	0.4	0.3	0.4		0.00	0.00	0.00	0.00	0.00					
21	日	12.5	12.5	12.5	12.5	13.0	0.60	0.61				0.65	0.59	0.54		0.62	0.63	0.6	0.6	0.5	0.5	0.6	0.3		7.01	7.02		7.20	7.06	7.03		7.29	0.4	0.3	0.5	0.4	0.3		0.00	0.00	0.00	0.00	0.00					
22	月	12.8	13.0	13.0	12.8	12.8	0.58	0.63				0.66	0.58	0.51		0.62	0.64	0.5	0.6	0.5	0.6	0.6	0.3		7.02	7.03		7.12	7.01	7.04		7.27	0.3	0.3	0.4	0.4	0.3		0.00	0.00	0.00	0.00	0.00					
23	火	12.2	12.8	12.6	12.7	11.9	0.61	0.61				0.60	0.60	0.51		0.62		0.5	0.6	0.5	0.5	0.6	0.3		7.02	7.02		7.05	7.04	7.06			0.3	0.3	0.4	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
24	水	13.2	13.5	13.2	13.4	13.0	0.59	0.60				0.59	0.59	0.51		0.63		0.5	0.6	0.5	0.5	0.6	0.3		7.02	7.03		7.04	7.02	7.03			0.4	0.4	0.3	0.4	0.3		0.00	0.00	0.00	0.00	0.00					
25	木	14.2	13.8	13.2	13.0	13.5	0.69	0.63				0.60	0.59	0.52		0.62		0.5	0.6	0.5	0.5	0.6	0.3		7.02	7.09		7.02	7.08	7.07			0.3	0.3	0.4	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
26	金	12.2	13.2	12.5	12.5	12.5	0.63	0.62				0.61	0.60	0.52		0.62		0.5	0.6	0.5	0.5	0.6	0.3		7.00	7.01		7.02	7.01	7.03			0.3	0.3	0.3	0.3	0.4		0.00	0.00	0.00	0.00	0.00					
27	土	13.0	13.2	13.2	13.0	13.3	0.60	0.61				0.60	0.60	0.51		0.62		0.5	0.6	0.5	0.6	0.6	0.3		7.05	7.04		7.04	7.04	7.04			0.3	0.3	0.4	0.4	0.4		0.00	0.00	0.00	0.00	0.00					
28	日	13.2	13.5	13.2	13.0	13.2	0.61	0.62				0.61	0.60	0.52		0.62		0.6	0.6	0.5	0.5	0.6	0.3		7.02	7.03		7.02	7.02	7.03			0.3	0.3	0.2	0.2	0.3		0.00	0.00	0.00	0.00	0.00					
29	金	13.1	13.3	13.2	13.0	13.2	0.63	0.63				0.60	0.60	0.52		0.62		0.5	0.6	0.5	0.6	0.6	0.3		7.06	7.04		7.04	7.04	7.05			0.2	0.3	0.3	0.2	0.2		0.00	0.00	0.00	0.00	0.00					
30	土	13.7	14.0	13.8	13.5	13.8	0.61	0.61				0.60	0.60	0.52		0.62		0.5	0.6	0.5	0.5	0.6	0.3		7.02	7.03		7.03	7.04	7.05			0.3	0.3	0.3	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
31	日	14.5	14.7	14.5	14.5	14.7	0.60	0.61				0.60	0.58	0.51		0.62		0.5	0.6	0.5	0.5	0.6	0.3		7.01	7.02		7.03	7.04	7.04			0.3	0.3	0.3	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
合計	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
平均	—	11.7	12.4	11.7	11.6	11.7	0.60	0.60				0.60	0.60	0.50		0.60	0.70	0.5	0.6	0.5	0.5	0.6	0.3		7.00	7.00		7.10	7.00	7.00		7.30	0.3	0.3	0.5	0.3	0.3		0.00	0.00	0.00	0.00	0.00					
最大	—	14.5	14.7	14.5	14.5	14.7	0.69	0.63				0.72	0.63	0.54		0.69	0.70	0.6	0.6	0.5	0.6	0.6	0.3		7.06	7.09		7.25	7.08	7.07		7.35	0.4	0.4</														

令和2年度 1月分 毎日水質検査集計表

(単位mg/L)

日	曜日	水温					残留塩素										市内残留塩素					NaClO 6.0%	pH値										色度					濁度								
		大阪水		高地区系	配水B	配水塔	高圧	大阪水		処理水			高地区系	配水B	配水塔	高圧	取石分岐	泉北土生	千代田	羽衣	東羽衣		綾園	取石	高砂3	大阪水		取石分岐	高地区系	配水B	配水塔	高圧	泉北土生	大阪水		高地区系	配水B	配水塔	高圧	大阪水		高地区系	配水B	配水塔	高圧	
		綾井	北					綾井	北	綾南	綾東	北														綾井	北							綾井	北					綾井	北					綾井
1	火	22.8	23.4	22.5	22.8	23.0	0.52	0.53				0.69	0.67	0.58		0.63	0.68	0.6	0.6	0.5	0.6	0.7	0.3		7.45	7.59		7.47	7.57	7.59		7.20	0.3	0.3	0.9	0.6	0.3		0.00	0.00	0.00	0.00	0.00			
2	水	22.8	23.5	22.5	23.0	22.5	0.59	0.59				0.70	0.70	0.58		0.61	0.69	0.6	0.6	0.6	0.6	0.7	0.3		7.69	7.70		7.50	7.61	7.71		7.23	0.3	0.4	1.0	0.8	0.4		0.00	0.00	0.00	0.00	0.00			
3	木	22.4	23.0	22.0	22.5	22.8	0.58	0.58				0.72	0.68	0.50		0.61	0.71	0.6	0.6	0.6	0.6	0.7	0.3		7.60	7.58		7.30	7.41	7.59		7.19	0.5	0.6	0.9	0.6	0.5		0.00	0.00	0.00	0.00	0.00			
4	金	22.3	23.0	22.0	22.5	22.3	0.55	0.56				0.70	0.66	0.56		0.62	0.71	0.6	0.6	0.6	0.6	0.7	0.3		7.62	7.61		7.35	7.53	7.61		7.22	0.4	0.4	1.0	0.7	0.4		0.00	0.00	0.00	0.00	0.00			
5	土	22.0	22.8	21.2	22.0	21.8	0.57	0.57				0.68	0.67	0.59		0.61	0.68	0.6	0.6	0.5	0.6	0.7	0.3		7.51	7.57		7.53	7.60	7.68		7.27	0.4	0.4	0.9	0.5	0.3		0.00	0.00	0.00	0.00	0.00			
6	日	21.8	22.2	21.2	21.9	22.0	0.58	0.58				0.69	0.65	0.54		0.62	0.70	0.6	0.6	0.5	0.6	0.7	0.3		7.44	7.55		7.54	7.62	7.61		7.28	0.4	0.4	0.9	0.6	0.4		0.00	0.00	0.00	0.00	0.00			
7	月	21.0	21.9	20.8	21.0	20.6	0.53	0.53				0.73	0.66	0.57		0.62	0.70	0.6	0.6	0.5	0.5	0.7	0.3		7.61	7.63		7.55	7.58	7.65		7.27	0.3	0.4	0.9	0.6	0.5		0.00	0.00	0.00	0.00	0.00			
8	火	21.1	22.0	21.1	21.1	21.9	0.57	0.55				0.71	0.69	0.51		0.62	0.68	0.6	0.6	0.5	0.5	0.7	0.3		7.58	7.57		7.28	7.39	7.57		7.27	0.4	0.5	1.0	0.8	0.5		0.00	0.00	0.00	0.00	0.00			
9	水	21.0	22.0	19.0	21.2	21.8	0.61	0.58				0.73	0.64	0.53		0.62	0.65	0.6	0.5	0.5	0.5	0.7	0.3		7.59	7.58		7.31	7.49	7.58		7.27	0.3	0.3	0.9	0.5	0.3		0.00	0.00	0.00	0.00	0.00			
10	木	21.2	22.1	18.8	21.4	22.5	0.58	0.59				0.68	0.65	0.56		0.61	0.67	0.6	0.6	0.5	0.5	0.7	0.3		7.52	7.51		7.29	7.46	7.51		7.31	0.3	0.3	0.9	0.5	0.3		0.00	0.00	0.00	0.00	0.00			
11	金	21.6	22.5	19.0	21.8	22.2	0.58	0.56				0.68	0.63	0.54		0.62	0.67	0.5	0.6	0.5	0.5	0.7	0.3		7.53	7.53		7.37	7.49	7.53		7.34	0.3	0.3	1.0	0.5	0.4		0.01	0.00	0.00	0.00	0.00			
12	土	22.2	23.0	19.0	22.2	22.5	0.58	0.59				0.69	0.63	0.56		0.62	0.68	0.5	0.5	0.5	0.5	0.7	0.3		7.71	7.72		7.60	7.69	7.74		7.33	0.3	0.4	0.9	0.6	0.4		0.01	0.01	0.01	0.01	0.00			
13	日	21.9	22.2	19.8	22.0	21.7	0.59	0.55				0.74	0.66	0.50		0.63	0.68	0.5	0.5	0.5	0.5	0.7	0.3		7.60	7.60		7.37	7.50	7.60		7.30	0.3	0.3	1.0	0.5	0.3		0.00	0.00	0.00	0.00	0.00			
14	月	22.2	22.2	19.8	22.0	22.0	0.58	0.59				0.69	0.62	0.55		0.63	0.68	0.5	0.5	0.5	0.5	0.7	0.3		7.69	7.62		7.42	7.58	7.68		7.31	0.4	0.4	1.0	0.6	0.4		0.00	0.00	0.00	0.00	0.00			
15	火	21.9	22.0	19.8	21.9	21.8	0.60	0.56				0.74	0.67	0.58		0.63	0.71	0.6	0.5	0.5	0.5	0.7	0.3		7.55	7.53		7.40	7.59	7.60		7.28	0.3	0.4	0.9	0.7	0.4		0.00	0.00	0.00	0.00	0.00			
16	水	21.3	21.7	19.8	21.3	21.0	0.57	0.56				0.69	0.66	0.58		0.64	0.70	0.6	0.5	0.5	0.5	0.7	0.3		7.54	7.53		7.27	7.42	7.45		7.28	0.3	0.4	1.0	0.6	0.4		0.00	0.00	0.00	0.00	0.00			
17	木	21.0	21.0	19.1	21.0	20.5	0.57	0.56				0.68	0.65	0.56		0.64	0.69	0.5	0.5	0.6	0.6	0.7	0.3		7.61	7.57		7.39	7.46	7.55		7.29	0.3	0.4	1.1	0.7	0.4		0.00	0.00	0.00	0.00	0.00			
18	金	19.5	20.0	20.0	20.0	18.9	0.52	0.66				0.72	0.65	0.50		0.65	0.69	0.6	0.5	0.4	0.5	0.7	0.3		7.68	7.70		7.44	7.59	7.67		7.27	0.4	0.4	1.0	0.7	0.4		0.00	0.00	0.01	0.00	0.00			
19	土	19.5	20.2	19.5	19.7	19.5	0.57	0.57				0.69	0.64	0.58		0.67	0.67	0.5	0.6	0.5	0.6	0.7	0.3		7.59	7.58		7.37	7.49	7.59		7.30	0.3	0.4	1.0	0.6	0.4		0.00	0.00	0.00	0.00	0.00			
20	日	19.0	19.7	19.3	19.0	18.8	0.59	0.61				0.68	0.65	0.59		0.64	0.64	0.6	0.6	0.5	0.6	0.7	0.3		7.55	7.56		7.39	7.50	7.58		7.33	0.4	0.4	1.1	0.7	0.4		0.01	0.00	0.00	0.00	0.00			
21	月	19.0	19.2	20.0	19.0	19.0	0.54	0.55				0.67	0.62	0.58		0.61	0.62	0.6	0.6	0.5	0.5	0.7	0.3		7.45	7.51		7.40	7.44	7.54		7.30	0.3	0.2	0.8	0.2	0.4		0.00	0.00	0.00	0.00	0.00			
22	火	18.0	18.9	19.9	18.3	17.9	0.51	0.56				0.65	0.63	0.57		0.60	0.62	0.6	0.6	0.5	0.6	0.7	0.3		7.46	7.54		7.50	7.37	7.55		7.29	0.3	0.3	1.1	0.5	0.3		0.02	0.02	0.03	0.03	0.02			
23	水	18.0	18.2	20.0	18.0	18.1	0.46	0.51				0.61	0.59	0.54		0.60	0.59	0.5	0.6	0.5	0.6	0.7	0.3		7.72	7.68		7.51	7.49	7.59		7.28	0.3	0.4	1.4	0.6	0.4		0.00	0.00	0.00	0.00	0.00			
24	木	18.0	19.0	20.6	18.3	18.0	0.56	0.57				0.67	0.66	0.55		0.63	0.64	0.6	0.5	0.5	0.6	0.7	0.3		7.45	7.45		7.25	7.39	7.44		7.15	0.3	0.3	2.2	0.6	0.3		0.00	0.00	0.00	0.00	0.00			
25	金	17.9	18.0	21.0	17.8	17.9	0.53	0.54				0.67	0.62	0.54		0.62	0.76	0.6	0.5	0.5	0.6	0.7	0.3		7.59	7.59		7.39	7.54	7.56		7.07	0.5	0.4	2.6	0.8	0.4		0.00	0.00	0.00	0.00	0.00			
26	土	17.0	18.0	20.5	17.2	17.2	0.54	0.55				0.67	0.61	0.54		0.62	0.71	0.6	0.6	0.5	0.6	0.7	0.3		7.63	7.66		7.41	7.52	7.58		7.07	0.4	0.4	2.8	0.8	0.5		0.00	0.00	0.01	0.00	0.00			
27	日	17.0	17.8	21.0	17.0	17.5	0.58	0.58				0.64	0.64	0.54		0.62	0.70	0.6	0.5	0.5	0.6	0.7	0.3		7.59	7.59		7.25	7.59	7.58		7.09	0.3	0.3	2.8	0.3	0.4		0.00	0.00	0.01	0.00	0.00			
28	月	17.2	17.8	21.0	17.0	17.2	0.53	0.55				0.63	0.59	0.57		0.67	0.67	0.6	0.5	0.5	0.6	0.7	0.3		7.51	7.52		7.34	7.53	7.55		7.06	0.3	0.3	2.3	0.3	0.4		0.02	0.01	0.02	0.02	0.01			
29	火	17.0	17.5	20.9	17.0	17.0	0.65	0.65				0.72	0.63	0.50		0.68	0.77	0.6	0.5	0.5	0.6	0.7	0.3		7.62	7.62		7.30	7.61	7.61		7.03	0.2	0.3	2.0	0.7	0.3		0.00	0.00	0.00	0.00	0.00			
30	水	17.0	17.4	21.5	17.2	16.8	0.62	0.63				0.67	0.64	0.58		0.68	0.75	0.6	0.5	0.5	0.5	0.7	0.3		7.67	7.66		7.37	7.68	7.69		7.07	0.3	0.3	2.4	0.3	0.3		0.00	0.00	0.01	0.00	0.00			
31	木	16.4	17.2	21.9	17.0	16.0	0.53	0.52				0.74	0.62	0.54		0.62	0.78	0.6	0.5	0.5	0.5	0.7	0.3		7.63	7.63		7.32	7.63	7.61		7.07	0.3	0.3	2.2	0.3	0.3		0.00	0.00	0.01	0.00	0.00			
合計		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
平均		20.0	20.6	20.5	20.1	20.1	0.60	0.60				0.70	0.60	0.60		0.60	0.70	0.5	0.6	0.5	0.6	0.7	0.3		7.60	7.60		7.40	7.50	7.60		7.20	0.3	0.4	1.4	0.6	0.4		0.00	0.00	0.00	0.00	0.00			

令和2年度 12月分 毎日水質検査集計表

(単位mg/L)

日	曜日	水温					残留塩素					市内残留塩素					NaClO 6.0%	pH値					色度					濁度																	
		大阪水		高地区系	配水B	配水塔	高圧	大阪水		処理水			高地区系	配水B	配水塔	高圧		取石分岐	泉北土生	千代田	羽衣	東羽衣	綾園	取石	高砂3	大阪水		高地区系	配水B	配水塔	高圧	泉北土生	大阪水		高地区系	配水B	配水塔	高圧	大阪水		高地区系	配水B	配水塔	高圧	
		綾井	北					綾井	北	綾南	綾東	北														綾井	北						綾井	北					綾井	北					綾井
				綾井	北	綾井	北						綾井	北	綾井	北		綾井	北	綾井	北	綾井	北	綾井	北			綾井	北	綾井	北	綾井			北	綾井	北	綾井			北	綾井	北	綾井	
1	火	22.8	23.4	22.5	22.8	23.0		0.52	0.53				0.69	0.67	0.58		0.63	0.68	0.5	0.5	0.5	0.7	0.7	0.3		7.45	7.59		7.47	7.57	7.59		7.20	0.3	0.3	0.9	0.6	0.3		0.00	0.00	0.00	0.00	0.00	
2	水	22.8	23.5	22.5	23.0	22.5		0.59	0.59				0.70	0.70	0.58		0.61	0.69	0.6	0.5	0.5	0.7	0.7	0.3		7.69	7.70		7.50	7.61	7.71		7.23	0.3	0.4	1.0	0.8	0.4		0.00	0.00	0.00	0.00	0.00	
3	木	22.4	23.0	22.0	22.5	22.8		0.58	0.58				0.72	0.68	0.50		0.61	0.71	0.6	0.5	0.5	0.7	0.7	0.3		7.60	7.58		7.30	7.41	7.59		7.19	0.5	0.6	0.9	0.6	0.5		0.00	0.00	0.00	0.00	0.00	
4	金	22.3	23.0	22.0	22.5	22.3		0.55	0.56				0.70	0.66	0.56		0.62	0.71	0.6	0.5	0.5	0.7	0.7	0.3		7.62	7.61		7.35	7.53	7.61		7.22	0.4	0.4	1.0	0.7	0.4		0.00	0.00	0.00	0.00	0.00	
5	土	22.0	22.8	21.2	22.0	21.8		0.57	0.57				0.68	0.67	0.59		0.61	0.68	0.6	0.6	0.5	0.7	0.7	0.3		7.51	7.57		7.53	7.60	7.68		7.27	0.4	0.4	0.9	0.5	0.3		0.00	0.00	0.00	0.00	0.00	
6	日	21.8	22.2	21.2	21.9	22.0		0.58	0.58				0.69	0.65	0.54		0.62	0.70	0.6	0.6	0.5	0.7	0.7	0.3		7.44	7.55		7.54	7.62	7.61		7.28	0.4	0.4	0.9	0.6	0.4		0.00	0.00	0.00	0.00	0.00	
7	月	21.0	21.9	20.8	21.0	20.6		0.53	0.53				0.73	0.66	0.57		0.62	0.70	0.6	0.6	0.5	0.6	0.7	0.3		7.61	7.63		7.55	7.58	7.65		7.27	0.3	0.4	0.9	0.6	0.5		0.00	0.00	0.00	0.00	0.00	
8	火	21.1	22.0	21.1	21.1	21.9		0.57	0.55				0.71	0.69	0.51		0.62	0.68	0.5	0.6	0.5	0.6	0.7	0.3		7.58	7.57		7.28	7.39	7.57		7.27	0.4	0.5	1.0	0.8	0.5		0.00	0.00	0.00	0.00	0.00	
9	水	21.0	22.0	19.0	21.2	21.8		0.61	0.58				0.73	0.64	0.53		0.62	0.65	0.5	0.6	0.5	0.6	0.7	0.3		7.59	7.58		7.31	7.49	7.58		7.27	0.3	0.3	0.9	0.5	0.3		0.00	0.00	0.00	0.00	0.00	
10	木	21.2	22.1	18.8	21.4	22.5		0.58	0.59				0.68	0.65	0.56		0.61	0.67	0.5	0.6	0.5	0.6	0.7	0.3		7.52	7.51		7.29	7.46	7.51		7.31	0.3	0.3	0.9	0.5	0.3		0.00	0.00	0.00	0.00	0.00	
11	金	21.6	22.5	19.0	21.8	22.2		0.58	0.56				0.68	0.63	0.54		0.62	0.67	0.6	0.5	0.5	0.6	0.7	0.3		7.53	7.53		7.37	7.49	7.53		7.34	0.3	0.3	1.0	0.5	0.4		0.01	0.00	0.00	0.00	0.00	
12	土	22.2	23.0	19.0	22.2	22.5		0.58	0.59				0.69	0.63	0.56		0.62	0.68	0.6	0.6	0.4	0.6	0.7	0.3		7.71	7.72		7.60	7.69	7.74		7.33	0.3	0.4	0.9	0.6	0.4		0.01	0.01	0.01	0.01	0.00	
13	日	21.9	22.2	19.8	22.0	21.7		0.59	0.55				0.74	0.66	0.50		0.63	0.68	0.6	0.6	0.4	0.6	0.7	0.3		7.60	7.60		7.37	7.50	7.60		7.30	0.3	0.3	1.0	0.5	0.3		0.00	0.00	0.00	0.00	0.00	
14	月	22.2	22.2	19.8	22.0	22.0		0.58	0.59				0.69	0.62	0.55		0.63	0.68	0.5	0.5	0.5	0.5	0.7	0.3		7.69	7.62		7.42	7.58	7.68		7.31	0.4	0.4	1.0	0.6	0.4		0.00	0.00	0.00	0.00	0.00	
15	火	21.9	22.0	19.8	21.9	21.8		0.60	0.56				0.74	0.67	0.58		0.63	0.71	0.5	0.6	0.5	0.5	0.7	0.3		7.55	7.53		7.40	7.59	7.60		7.28	0.3	0.4	0.9	0.7	0.4		0.00	0.00	0.00	0.00	0.00	
16	水	21.3	21.7	19.8	21.3	21.0		0.57	0.56				0.69	0.66	0.58		0.64	0.70	0.6	0.6	0.5	0.5	0.7	0.3		7.54	7.53		7.27	7.42	7.45		7.28	0.3	0.4	1.0	0.6	0.4		0.00	0.00	0.00	0.00	0.00	
17	木	21.0	21.0	19.1	21.0	20.5		0.57	0.56				0.68	0.65	0.56		0.64	0.69	0.6	0.6	0.5	0.5	0.7	0.3		7.61	7.57		7.39	7.46	7.55		7.29	0.3	0.4	1.1	0.7	0.4		0.00	0.00	0.00	0.00	0.00	
18	金	19.5	20.0	20.0	20.0	18.9		0.52	0.66				0.72	0.65	0.50		0.65	0.69	0.6	0.6	0.5	0.6	0.7	0.3		7.68	7.70		7.44	7.59	7.67		7.27	0.4	0.4	1.0	0.7	0.4		0.00	0.00	0.01	0.00	0.00	
19	土	19.5	20.2	19.5	19.7	19.5		0.57	0.57				0.69	0.64	0.58		0.67	0.67	0.6	0.5	0.5	0.5	0.7	0.3		7.59	7.58		7.37	7.49	7.59		7.30	0.3	0.4	1.0	0.6	0.4		0.00	0.00	0.00	0.00	0.00	
20	日	19.0	19.7	19.3	19.0	18.8		0.59	0.61				0.68	0.65	0.59		0.64	0.64	0.6	0.6	0.5	0.5	0.7	0.3		7.55	7.56		7.39	7.50	7.58		7.33	0.4	0.4	1.1	0.7	0.4		0.01	0.00	0.00	0.00	0.00	
21	月	19.0	19.2	20.0	19.0	19.0		0.54	0.55				0.67	0.62	0.58		0.61	0.62	0.6	0.6	0.5	0.5	0.7	0.3		7.45	7.51		7.40	7.44	7.54		7.30	0.3	0.2	0.8	0.2	0.4		0.00	0.00	0.00	0.00	0.00	
22	火	18.0	18.9	19.9	18.3	17.9		0.51	0.56				0.65	0.63	0.57		0.60	0.62	0.6	0.6	0.5	0.5	0.7	0.3		7.46	7.54		7.50	7.37	7.55		7.29	0.3	0.3	1.1	0.5	0.3		0.02	0.02	0.03	0.03	0.02	
23	水	18.0	18.2	20.0	18.0	18.1		0.46	0.51				0.61	0.59	0.54		0.60	0.59	0.6	0.6	0.5	0.5	0.7	0.3		7.72	7.68		7.51	7.49	7.59		7.28	0.3	0.4	1.4	0.6	0.4		0.00	0.00	0.00	0.00	0.00	
24	木	18.0	19.0	20.6	18.3	18.0		0.56	0.57				0.67	0.66	0.55		0.63	0.64	0.6	0.6	0.5	0.6	0.7	0.3		7.45	7.45		7.25	7.39	7.44		7.15	0.3	0.3	2.2	0.6	0.3		0.00	0.00	0.00	0.00	0.00	
25	金	17.9	18.0	21.0	17.8	17.9		0.53	0.54				0.67	0.62	0.54		0.62	0.76	0.6	0.6	0.5	0.6	0.7	0.3		7.59	7.59		7.39	7.54	7.56		7.07	0.5	0.4	2.6	0.8	0.4		0.00	0.00	0.00	0.00	0.00	
26	土	17.0	18.0	20.5	17.2	17.2		0.54	0.55				0.67	0.61	0.54		0.62	0.71	0.6	0.6	0.5	0.7	0.7	0.3		7.63	7.66		7.41	7.52	7.58		7.07	0.4	0.4	2.8	0.8	0.5		0.00	0.00	0.01	0.00	0.00	
27	日	17.0	17.8	21.0	17.0	17.5		0.58	0.58				0.64	0.64	0.54		0.62	0.70	0.6	0.6	0.5	0.6	0.7	0.3		7.59	7.59		7.25	7.59	7.58		7.09	0.3	0.3	2.8	0.3	0.4		0.00	0.00	0.01	0.00	0.00	
28	月	17.2	17.8	21.0	17.0	17.2		0.53	0.55				0.63	0.59	0.57		0.67	0.67	0.6	0.6	0.5	0.6	0.7	0.3		7.51	7.52		7.34	7.53	7.55		7.06	0.3	0.3	2.3	0.3	0.4		0.02	0.01	0.02	0.02	0.01	
29	火	17.0	17.5	20.9	17.0	17.0		0.65	0.65				0.72	0.63	0.50		0.68	0.77	0.6	0.6	0.5	0.6	0.7	0.3		7.62	7.62		7.30	7.61	7.61		7.03	0.2	0.3	2.0	0.7	0.3		0.00	0.00	0.00	0.00	0.00	
30	水	17.0	17.4	21.5	17.2	16.8		0.62	0.63				0.67	0.64	0.58		0.68	0.75	0.6	0.6	0.5	0.6	0.7	0.3		7.67	7.66		7.37	7.68	7.69		7.07	0.3	0.3	2.4	0.3	0.3		0.00	0.00	0.01	0.00	0.00	
31	木	16.4	17.2	21.9	17.0	16.0		0.53	0.52				0.74	0.62	0.54		0.62	0.78	0.6	0.6	0.5	0.6	0.7	0.3		7.63	7.63		7.32	7.63	7.61		7.07	0.3	0.3	2.2	0.3	0.3		0.00	0.00	0.01	0.00	0.00	
合計		-	-	-	-	-		-	-				-	-	-		-	-	-	-	-</																								

令和2年度 11月分 毎日水質検査集計表

(単位mg/l)

日	曜日	水温					残留塩素										NaClO		pH値						色度					濁度												
		大阪水		高地区系	配水B	配水塔	高圧	大阪水		処理水			高地区系	配水B	配水塔	高圧	取石分岐	泉北土生	千代田	羽衣	東羽衣	綾園	取石	高砂3	6.0%	大阪水		取石分岐	高地区系	配水B	配水塔	高圧	泉北土生	大阪水		高地区系	配水B	配水塔	高圧			
		綾井	北	綾井	北	綾南		綾東	綾井	北	綾井	北														綾井	北							綾井	北					綾井	北	
		綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	綾井	北	
1	日	24.0	24.1	22.5	24.1	24.0	0.81	0.81				0.69	0.76	0.67		0.68	0.65	0.6	0.6	0.6	0.7	0.7	0.3		7.02	7.03	7.47	7.02	7.04		7.13	0.5	0.5	0.9	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
2	月	24.2	24.0	22.5	24.2	24.0	0.72	0.71				0.70	0.76	0.65		0.67	0.66	0.5	0.6	0.6	0.7	0.7	0.3		7.01	7.07	7.50	7.04	7.02		7.15	0.5	0.4	1.0	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
3	火	24.0	24.2	22.0	24.2	24.0	0.81	0.82				0.72	0.77	0.68		0.69	0.59	0.6	0.6	0.6	0.7	0.7	0.3		7.01	7.03	7.30	7.03	7.04		7.17	0.4	0.4	0.9	0.5	0.4	0.00	0.00	0.00	0.00	0.00	
4	水	24.0	24.0	22.0	24.2	24.0	0.71	0.74				0.70	0.76	0.67		0.68	0.68	0.6	0.6	0.6	0.7	0.7	0.3		7.02	7.01	7.35	7.05	7.06		7.17	0.4	0.3	1.0	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
5	木	24.0	24.0	21.2	24.5	24.5	0.72	0.72				0.68	0.75	0.69		0.68	0.64	0.6	0.6	0.6	0.6	0.7	0.3		7.01	7.01	7.53	7.04	7.05		7.14	0.4	0.4	0.9	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
6	金	24.0	24.5	21.2	24.5	24.5	0.80	0.81				0.69	0.77	0.65		0.69	0.64	0.6	0.6	0.6	0.7	0.7	0.3		7.03	7.05	7.54	7.09	7.10		7.16	0.4	0.4	0.9	0.5	0.4	0.00	0.00	0.00	0.00	0.00	
7	土	23.5	23.5	20.8	23.5	24.0	0.72	0.72				0.73	0.75	0.68		0.68	0.65	0.6	0.6	0.5	0.8	0.7	0.3		7.03	7.03	7.55	7.04	7.04		7.12	0.5	0.5	0.9	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
8	日	23.5	23.5	21.1	23.5	24.0	0.81	0.82				0.71	0.76	0.68		0.75	0.65	0.6	0.6	0.6	0.7	0.7	0.3		7.02	7.03	7.28	7.04	7.05		7.10	0.4	0.4	1.0	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
9	月	23.0	23.1	19.0	23.0	23.2	0.74	0.75				0.73	0.74	0.68		0.77	0.56	0.6	0.6	0.6	0.8	0.7	0.3		7.03	7.00	7.31	7.01	7.02		7.09	0.4	0.4	0.9	0.3	0.3	0.00	0.00	0.00	0.00	0.00	
10	火	23.5	24.0	18.8	23.5	24.0	0.80	0.81				0.68	0.76	0.65		0.75	0.61	0.6	0.6	0.6	0.7	0.7	0.3		7.00	7.01	7.29	7.05	7.06		7.04	0.5	0.5	0.9	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
11	水	23.0	23.0	19.0	23.0	23.5	0.75	0.74				0.68	0.72	0.66		0.77	0.63	0.6	0.6	0.6	0.7	0.7	0.3		7.03	7.00	7.37	7.00	7.02		7.01	0.4	0.4	1.0	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
12	木	23.0	23.5	19.0	23.0	24.0	0.81	0.82				0.69	0.79	0.67		0.78	0.60	0.6	0.6	0.6	0.7	0.7	0.3		7.01	7.03	7.60	7.05	7.06		6.98	0.4	0.4	0.9	0.5	0.5	0.00	0.00	0.01	0.00	0.00	
13	金	23.0	23.0	19.8	22.5	22.5	0.78	0.78				0.74	0.79	0.70		0.79	0.61	0.6	0.6	0.6	0.7	0.7	0.3		6.99	6.99	7.37	7.02	7.03		6.96	0.3	0.3	1.0	0.3	0.3	0.00	0.00	0.00	0.00	0.00	
14	土	22.8	22.8	19.8	22.5	23.0	0.80	0.80				0.69	0.81	0.70		0.79	0.69	0.6	0.6	0.6	0.6	0.7	0.3		6.99	6.98	7.42	6.95	7.02		6.93	0.5	0.5	1.0	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
15	日	22.2	22.4	19.8	22.4	22.4	0.81	0.80				0.74	0.79	0.71		0.80	0.65	0.6	0.6	0.6	0.8	0.7	0.3		7.02	7.00	7.40	7.01	7.02		6.94	0.4	0.4	0.9	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
16	月	23.2	23.0	19.8	23.6	24.0	0.82	0.83				0.69	0.78	0.70		0.81	0.66	0.6	0.6	0.6	0.8	0.7	0.3		6.99	7.03	7.27	7.04	7.05		6.93	0.4	0.5	1.0	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
17	火	22.9	23.2	19.1	22.9	23.5	0.82	0.81				0.68	0.80	0.70		0.81	0.65	0.6	0.6	0.5	0.7	0.7	0.3		7.01	7.01	7.39	7.02	7.02		6.95	0.3	0.3	1.1	0.3	0.4	0.00	0.00	0.00	0.00	0.00	
18	水	22.2	22.5	20.0	22.7	23.0	0.84	0.83				0.72	0.80	0.70		0.79	0.66	0.6	0.6	0.5	0.7	0.7	0.3		7.02	7.02	7.44	7.04	7.03		6.95	0.4	0.4	1.0	0.4	0.4	0.00	0.00	0.01	0.00	0.00	
19	木	22.6	22.7	19.5	22.2	23.1	0.83	0.81				0.69	0.80	0.73		0.80	0.66	0.6	0.6	0.6	0.7	0.7	0.3		7.01	7.00	7.37	7.00	7.01		6.94	0.3	0.3	1.0	0.3	0.3	0.00	0.00	0.00	0.00	0.00	
20	金	23.5	23.5	19.3	23.5	24.0	0.78	0.78				0.68	0.80	0.71		0.80	0.64	0.5	0.5	0.6	0.7	0.7	0.3		7.00	7.00	7.39	7.01	7.01		6.97	0.5	0.5	1.1	0.5	0.5	0.00	0.00	0.00	0.00	0.00	
21	土	23.8	24.0	20.0	24.2	24.0	0.78	0.79				0.67	0.80	0.68		0.80	0.66	0.6	0.6	0.6	0.7	0.7	0.3		7.00	7.00	7.40	7.02	6.99		7.01	0.4	0.4	0.8	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
22	日	24.0	24.0	19.9	23.8	24.0	0.80	0.80				0.65	0.81	0.70		0.79	0.61	0.6	0.6	0.6	0.7	0.7	0.3		6.98	6.99	7.50	7.01	7.02		7.05	0.4	0.4	1.1	0.5	0.5	0.00	0.00	0.03	0.00	0.00	
23	月	24.1	24.1	20.0	24.2	24.2	0.84	0.83				0.61	0.80	0.70		0.78	0.67	0.6	0.5	0.6	0.7	0.7	0.3		7.00	7.00	7.51	7.01	7.03		7.04	0.4	0.4	1.4	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
24	火	24.8	24.8	20.6	24.8	24.5	0.82	0.81				0.67	0.81	0.69		0.77	0.62	0.6	0.5	0.6	0.7	0.7	0.3		7.01	7.00	7.25	7.00	7.02		7.04	0.4	0.4	2.2	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
25	水	25.0	25.0	21.0	25.0	24.6	0.77	0.79				0.67	0.75	0.68		0.76	0.64	0.5	0.5	0.5	0.7	0.7	0.3		6.97	6.98	7.39	7.00	7.01		6.98	0.4	0.3	2.6	0.3	0.3	0.00	0.00	0.00	0.00	0.00	
26	木	24.9	25.0	20.5	25.1	24.4	0.87	0.85				0.67	0.80	0.65		0.78	0.63	0.6	0.6	0.5	0.7	0.7	0.3		7.03	7.00	7.41	7.00	7.03		6.98	0.4	0.4	2.8	0.4	0.3	0.00	0.00	0.01	0.00	0.00	
27	金	25.0	25.0	21.0	25.0	25.0	0.79	0.78				0.64	0.78	0.70		0.78	0.64	0.6	0.5	0.5	0.7	0.7	0.3		7.03	7.03	7.25	7.00	7.00		6.94	0.5	0.5	2.8	0.5	0.5	0.00	0.00	0.01	0.00	0.00	
28	土	25.0	25.0	21.0	25.0	25.2	0.78	0.80				0.63	0.76	0.66		0.77	0.65	0.6	0.6	0.5	0.7	0.7	0.3		7.00	6.99	7.34	7.00	7.03		6.94	0.5	0.5	2.3	0.5	0.4	0.00	0.00	0.02	0.00	0.00	
29	日	25.0	25.0	20.9	25.0	25.5	0.80	0.81				0.72	0.76	0.67		0.76	0.61	0.6	0.5	0.5	0.7	0.7	0.3		6.98	6.96	7.30	6.92	6.95		6.95	0.4	0.4	2.0	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
30	月	24.2	24.8	21.5	24.2	25.0	0.80	0.81				0.67	0.79	0.67		0.76	0.64	0.6	0.5	0.5	0.7	0.7	0.3		6.99	6.98	7.37	7.00	7.02		6.89	0.4	0.4	2.4	0.4	0.4	0.00	0.00	0.01	0.00	0.00	
合計		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
平均		23.7	23.8	20.4	23.8	24.0	0.80	0.80				0.70	0.80	0.70		0.80	0.60	0.6	0.6	0.6	0.7	0.7	0.3		7.00	7.00	7.40	7.00	7.00		7.00	0.4	0.4	1.3	0.4	0.4	0.00	0.00	0.00	0.00	0.00	
最大		25.0	25.0	22.5	25.1	25.5	0.87	0.85				0.74	0.81	0.73		0.81	0.69	0.6	0.6	0.6	0.8	0.7	0.3		7.03	7.07	7.60	7.09	7.10		7.17	0.5	0.5	2.8	0.5	0.5	0.00	0.00	0.03	0.00	0.00	
最小		22.2	22.4	18.8	22.2	22.4	0.71	0.71				0.61	0.72	0.65		0.67	0.56	0.5	0.5	0.5	0.6	0.7	0.3		6.97	6.96	7.25	6.92	6.95		6.89	0.3	0.3	0.8	0.3	0.3	0.00	0.00	0.00	0.00	0.00	
備考		</																																								

令和2年度 9月分 毎日水質検査集計表

(単位mg/L)

日	曜日	水温					残留塩素					市内残留塩素					NaClO 6.0%	pH値					色度					濁度																		
		大阪水		高地区系	配水B	配水塔	高圧	大阪水		処理水			高地区系	配水B	配水塔	高圧		取石分岐	泉北土生	千代田	羽衣	東羽衣	綾園	取石	高砂3	大阪水		高地区系	配水B	配水塔	高圧	泉北土生	大阪水		高地区系	配水B	配水塔	高圧	大阪水		高地区系	配水B	配水塔	高圧		
		綾井	北					綾井	北	綾南	綾東	北					綾井									北	綾井						北	綾井					北	綾井					北	綾井
1	火	24.0	24.1	24.0	24.1	24.0	0.81	0.81				0.70	0.76	0.67		0.68	0.65	0.5	0.5	0.5	0.6	0.7	0.3		7.02	7.03		7.12	7.02	7.04		7.13	0.5	0.5	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00			
2	水	24.2	24.0	24.0	24.2	24.0	0.72	0.71				0.68	0.76	0.65		0.67	0.66	0.6	0.5	0.5	0.7	0.7	0.3		7.01	7.07		7.18	7.04	7.02		7.15	0.5	0.4	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00			
3	木	24.0	24.2	24.5	24.2	24.0	0.81	0.82				0.65	0.77	0.68		0.69	0.59	0.6	0.5	0.5	0.7	0.7	0.3		7.01	7.03		7.05	7.03	7.04		7.17	0.4	0.4	0.8	0.5	0.4		0.00	0.00	0.00	0.00	0.00			
4	金	24.0	24.0	24.4	24.2	24.0	0.71	0.74				0.70	0.76	0.67		0.68	0.68	0.6	0.5	0.5	0.7	0.7	0.3		7.02	7.01		7.12	7.05	7.06		7.17	0.4	0.3	0.6	0.4	0.4		0.00	0.00	0.00	0.00	0.00			
5	土	24.0	24.0	24.5	24.5	24.5	0.72	0.72				0.70	0.75	0.69		0.68	0.64	0.6	0.5	0.5	0.8	0.7	0.3		7.01	7.01		7.13	7.04	7.05		7.14	0.4	0.4	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00			
6	日	24.0	24.5	25.0	24.5	24.5	0.80	0.81				0.68	0.77	0.65		0.69	0.64	0.6	0.5	0.6	0.8	0.7	0.3		7.03	7.05		7.19	7.09	7.10		7.16	0.4	0.4	0.8	0.5	0.4		0.00	0.00	0.00	0.00	0.00			
7	月	23.5	23.5	23.5	23.5	24.0	0.72	0.72				0.69	0.75	0.68		0.68	0.65	0.6	0.5	0.5	0.7	0.7	0.3		7.03	7.03		7.14	7.04	7.04		7.12	0.5	0.5	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00			
8	火	23.5	23.5	23.5	23.5	24.0	0.81	0.82				0.68	0.76	0.68		0.75	0.65	0.6	0.5	0.5	0.7	0.7	0.3		7.02	7.03		7.12	7.04	7.05		7.10	0.4	0.4	0.7	0.4	0.4		0.00	0.00	0.00	0.00	0.00			
9	水	23.0	23.1		23.0	23.2	0.74	0.75				0.74	0.68		0.77	0.56	0.6	0.5	0.5	0.7	0.7	0.3		7.03	7.00		7.01	7.02	7.09		7.09	0.4	0.4		0.3	0.3		0.00	0.00		0.00	0.00				
10	木	23.5	24.0		23.5	24.0	0.80	0.81				0.76	0.65		0.75	0.61	0.6	0.5	0.5	0.8	0.7	0.3		7.00	7.01		7.05	7.06	7.04		7.04	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
11	金	23.0	23.0		23.0	23.5	0.75	0.74				0.72	0.66		0.77	0.63	0.6	0.5	0.6	0.8	0.7	0.3		7.03	7.00		7.00	7.02	7.01		7.01	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
12	土	23.0	23.5		23.0	24.0	0.81	0.82				0.79	0.67		0.78	0.60	0.6	0.6	0.6	0.8	0.7	0.3		7.01	7.03		7.05	7.06	6.98		6.98	0.4	0.4		0.5	0.5		0.00	0.00		0.00	0.00				
13	日	23.0	23.0		22.5	22.5	0.78	0.78				0.79	0.70		0.79	0.61	0.6	0.6	0.6	0.7	0.7	0.3		6.99	6.99		7.02	7.03	6.96		6.96	0.3	0.3		0.3	0.3		0.00	0.00		0.00	0.00				
14	月	22.8	22.8		22.5	23.0	0.80	0.80				0.81	0.70		0.79	0.69	0.6	0.5	0.6	0.6	0.7	0.3		6.99	6.98		6.95	7.02	6.93		6.93	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
15	火	22.2	22.4		22.4	22.4	0.81	0.80				0.79	0.71		0.80	0.65	0.6	0.6	0.6	0.7	0.7	0.3		7.02	7.00		7.01	7.02	6.94		6.94	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
16	水	23.2	23.0		23.6	24.0	0.82	0.83				0.78	0.70		0.81	0.66	0.6	0.5	0.6	0.8	0.7	0.3		6.99	7.03		7.04	7.05	6.93		6.93	0.4	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
17	木	22.9	23.2		22.9	23.5	0.82	0.81				0.80	0.70		0.81	0.65	0.6	0.6	0.6	0.7	0.7	0.3		7.01	7.01		7.02	7.02	6.95		6.95	0.3	0.3		0.3	0.4		0.00	0.00		0.00	0.00				
18	金	22.2	22.5		22.7	23.0	0.84	0.83				0.80	0.70		0.79	0.66	0.6	0.6	0.6	0.7	0.7	0.3		7.02	7.02		7.04	7.03	6.95		6.95	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
19	土	22.6	22.7		22.2	23.1	0.83	0.81				0.80	0.73		0.80	0.66	0.6	0.6	0.6	0.8	0.7	0.3		7.01	7.00		7.00	7.01	6.94		6.94	0.3	0.3		0.3	0.3		0.00	0.00		0.00	0.00				
20	日	23.5	23.5		23.5	24.0	0.78	0.78				0.80	0.71		0.80	0.64	0.6	0.6	0.6	0.7	0.7	0.3		7.00	7.00		7.01	7.01	6.97		6.97	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
21	月	23.8	24.0		24.2	24.0	0.78	0.79				0.80	0.68		0.80	0.66	0.6	0.6	0.6	0.7	0.7	0.3		7.00	7.00		7.02	6.99	7.01		7.01	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
22	火	24.0	24.0		23.8	24.0	0.80	0.80				0.81	0.70		0.79	0.61	0.6	0.6	0.6	0.7	0.7	0.3		6.98	6.99		7.01	7.02	7.05		7.05	0.4	0.4		0.5	0.5		0.00	0.00		0.00	0.00				
23	水	24.1	24.1		24.2	24.2	0.84	0.83				0.80	0.70		0.78	0.67	0.6	0.6	0.6	0.8	0.7	0.3		7.00	7.00		7.01	7.03	7.04		7.04	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
24	木	24.8	24.8		24.8	24.5	0.82	0.81				0.81	0.69		0.77	0.62	0.6	0.6	0.6	0.7	0.7	0.3		7.01	7.00		7.00	7.02	7.04		7.04	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
25	金	25.0	25.0		25.0	24.6	0.77	0.79				0.75	0.68		0.76	0.64	0.6	0.6	0.6	0.7	0.7	0.3		6.97	6.98		7.00	7.01	6.98		6.98	0.4	0.3		0.3	0.3		0.00	0.00		0.00	0.00				
26	土	24.9	25.0		25.1	24.4	0.87	0.85				0.80	0.65		0.78	0.63	0.6	0.5	0.6	0.8	0.7	0.3		7.03	7.00		7.00	7.03	6.98		6.98	0.4	0.4		0.4	0.3		0.00	0.00		0.00	0.00				
27	日	25.0	25.0		25.0	25.0	0.79	0.78				0.78	0.70		0.78	0.64	0.6	0.6	0.6	0.8	0.7	0.3		7.03	7.03		7.00	7.00	6.94		6.94	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
28	月	25.0	25.0		25.0	25.2	0.78	0.80				0.76	0.66		0.77	0.65	0.6	0.6	0.6	0.7	0.7	0.3		7.00	6.99		7.00	7.03	6.94		6.94	0.5	0.5		0.5	0.4		0.00	0.00		0.00	0.00				
29	火	25.0	25.0		25.0	25.5	0.80	0.81				0.76	0.67		0.76	0.61	0.6	0.6	0.6	0.6	0.7	0.3		6.98	6.96		6.92	6.95	6.95		6.95	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
30	水	24.2	24.8		24.2	25.0	0.80	0.81				0.79	0.67		0.76	0.64	0.6	0.6	0.5	0.7	0.8	0.3		6.99	6.98		7.00	7.02	6.89		6.89	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
		24.8	25.0		24.8	25.0	0.78	0.74				0.79	0.66		0.77	0.60									6.95	6.91		6.94	6.92	6.90		6.90	0.4	0.4		0.5	0.5		0.00	0.00		0.00	0.00			
合計		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
平均		23.8	23.9	24.2	23.8	24.0	0.80	0.80				0.70	0.80	0.70		0.80	0.60	0.5	0.6	0.6	0.7	0.7	0.3		7.00	7.00		7.10	7.00	7.00		7.00	0.4	0.4	0.8	0.4	0.4		0.00	0.00	0.00	0.00	0.00			
最大		25.0	25.0	25.0	25.1	25.5	0.87	0.85				0.70	0.81	0.73		0.81	0.69	0.6	0.6	0.6	0.8	0.8	0.3		7.03	7.07		7.19	7.09	7.10		7.17	0.5	0.5	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00			
最小		22.2	22.4	23.5	22.2	22.4	0.71	0.71				0.65	0.72	0.65		0.67	0.56	0.5	0.5	0.5	0.6	0.7	0.3		6.95																					

令和2年度 7月分 毎日水質検査集計表

(単位mg/l)

日	曜日	水温					残留塩素							市内残留塩素					NaClO 6.0%	pH値							色度					濁度													
		大阪水		高地区系	配水B	配水塔	高圧	大阪水		処理水			高地区系	配水B	配水塔	高圧	取石分岐	泉北土牛		千代田	羽衣	東羽衣	綾園	取石	高砂3	大阪水		高地区系	配水B	配水塔	高圧	泉北土牛	大阪水		高地区系	配水B	配水塔	高圧	大阪水		高地区系	配水B	配水塔	高圧	
		綾井	北					綾井	北	綾南	綾東	北														綾井	北						綾井	北					綾井	北					綾井
1	水	24.0	24.1	24.0	24.1	24.0	0.81	0.81				0.70	0.76	0.67		0.68	0.65	0.6	0.5	0.5	0.6	0.6	0.3		7.02	7.03		7.12	7.02	7.04		7.13	0.5	0.5	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00		
2	木	24.2	24.0	24.0	24.2	24.0	0.72	0.71				0.68	0.76	0.65		0.67	0.66	0.5	0.5	0.5	0.6	0.6	0.3		7.01	7.07		7.18	7.04	7.02		7.15	0.5	0.4	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00		
3	金	24.0	24.2	24.5	24.2	24.0	0.81	0.82				0.65	0.77	0.68		0.69	0.59	0.5	0.5	0.6	0.7	0.5	0.3		7.01	7.03		7.05	7.03	7.04		7.17	0.4	0.4	0.8	0.5	0.4		0.00	0.00	0.00	0.00	0.00		
4	土	24.0	24.0	24.4	24.2	24.0	0.71	0.74				0.70	0.76	0.67		0.68	0.68	0.5	0.5	0.5	0.6	0.6	0.3		7.02	7.01		7.12	7.05	7.06		7.17	0.4	0.3	0.6	0.4	0.4		0.00	0.00	0.00	0.00	0.00		
5	日	24.0	24.0	24.5	24.5	24.5	0.72	0.72				0.70	0.75	0.69		0.68	0.64	0.5	0.5	0.6	0.6	0.6	0.3		7.01	7.01		7.13	7.04	7.05		7.14	0.4	0.4	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00		
6	月	24.0	24.5	25.0	24.5	24.5	0.80	0.81				0.68	0.77	0.65		0.69	0.64	0.5	0.5	0.5	0.6	0.6	0.3		7.03	7.05		7.19	7.09	7.10		7.16	0.4	0.4	0.8	0.5	0.4		0.00	0.00	0.00	0.00	0.00		
7	火	23.5	23.5	23.5	23.5	24.0	0.72	0.72				0.69	0.75	0.68		0.68	0.65	0.5	0.5	0.5	0.7	0.6	0.3		7.03	7.03		7.14	7.04	7.04		7.12	0.5	0.5	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00		
8	水	23.5	23.5	23.5	23.5	24.0	0.81	0.82				0.68	0.76	0.68		0.75	0.65	0.5	0.5	0.5	0.6	0.6	0.3		7.02	7.03		7.12	7.04	7.05		7.10	0.4	0.4	0.7	0.4	0.4		0.00	0.00	0.00	0.00	0.00		
9	木	23.0	23.1		23.0	23.2	0.74	0.75				0.74	0.68		0.77	0.56	0.6	0.5	0.5	0.7	0.6	0.3		7.03	7.00		7.01	7.02		7.09	0.4	0.4		0.3	0.3		0.00	0.00		0.00	0.00				
10	金	23.5	24.0		23.5	24.0	0.80	0.81				0.76	0.65		0.75	0.61	0.6	0.5	0.5	0.7	0.5	0.3		7.00	7.01		7.05	7.06		7.04	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
11	土	23.0	23.0		23.0	23.5	0.75	0.74				0.72	0.66		0.77	0.63	0.6	0.5	0.5	0.7	0.5	0.3		7.03	7.00		7.00	7.02		7.01	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
12	日	23.0	23.5		23.0	24.0	0.81	0.82				0.79	0.67		0.78	0.60	0.6	0.5	0.6	0.7	0.5	0.3		7.01	7.03		7.05	7.06		6.98	0.4	0.4		0.5	0.5		0.00	0.00		0.00	0.00				
13	月	23.0	23.0		22.5	22.5	0.78	0.78				0.79	0.70		0.79	0.61	0.6	0.5	0.6	0.7	0.5	0.3		6.99	6.99		7.02	7.03		6.96	0.3	0.3		0.3	0.3		0.00	0.00		0.00	0.00				
14	火	22.8	22.8		22.5	23.0	0.80	0.80				0.81	0.70		0.79	0.69	0.6	0.5	0.5	0.7	0.5	0.3		6.99	6.98		6.95	7.02		6.93	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
15	水	22.2	22.4		22.4	22.4	0.81	0.80				0.79	0.71		0.80	0.65	0.6	0.6	0.5	0.7	0.5	0.3		7.02	7.00		7.01	7.02		6.94	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
16	木	23.2	23.0		23.6	24.0	0.82	0.83				0.78	0.70		0.81	0.66	0.6	0.6	0.6	0.7	0.6	0.3		6.99	7.03		7.04	7.05		6.93	0.4	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
17	金	22.9	23.2		22.9	23.5	0.82	0.81				0.80	0.70		0.81	0.65	0.6	0.6	0.6	0.7	0.5	0.3		7.01	7.01		7.02	7.02		6.95	0.3	0.3		0.3	0.4		0.00	0.00		0.00	0.00				
18	土	22.2	22.5		22.7	23.0	0.84	0.83				0.80	0.70		0.79	0.66	0.6	0.6	0.6	0.7	0.5	0.3		7.02	7.02		7.04	7.03		6.95	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
19	日	22.6	22.7		22.2	23.1	0.83	0.81				0.80	0.73		0.80	0.66	0.6	0.6	0.6	0.7	0.5	0.3		7.01	7.00		7.00	7.01		6.94	0.3	0.3		0.3	0.3		0.00	0.00		0.00	0.00				
20	月	23.5	23.5		23.5	24.0	0.78	0.78				0.80	0.71		0.80	0.64	0.6	0.6	0.5	0.7	0.5	0.3		7.00	7.00		7.01	7.01		6.97	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
21	火	23.8	24.0		24.2	24.0	0.78	0.79				0.80	0.68		0.80	0.66	0.6	0.6	0.5	0.7	0.5	0.3		7.00	7.00		7.02	6.99		7.01	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
22	水	24.0	24.0		23.8	24.0	0.80	0.80				0.81	0.70		0.79	0.61	0.6	0.6	0.5	0.7	0.5	0.3		6.98	6.99		7.01	7.02		7.05	0.4	0.4		0.5	0.5		0.00	0.00		0.00	0.00				
23	木	24.1	24.1		24.2	24.2	0.84	0.83				0.80	0.70		0.78	0.67	0.6	0.6	0.5	0.7	0.6	0.3		7.00	7.00		7.01	7.03		7.04	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
24	金	24.8	24.8		24.8	24.5	0.82	0.81				0.81	0.69		0.77	0.62	0.5	0.6	0.6	0.7	0.5	0.3		7.01	7.00		7.00	7.02		7.04	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
25	土	25.0	25.0		25.0	24.6	0.77	0.79				0.75	0.68		0.76	0.64	0.6	0.6	0.6	0.7	0.5	0.3		6.97	6.98		7.00	7.01		6.98	0.4	0.3		0.3	0.3		0.00	0.00		0.00	0.00				
26	日	24.9	25.0		25.1	24.4	0.87	0.85				0.80	0.65		0.78	0.63	0.6	0.5	0.6	0.7	0.5	0.3		7.03	7.00		7.00	7.03		6.98	0.4	0.4		0.4	0.3		0.00	0.00		0.00	0.00				
27	月	25.0	25.0		25.0	25.0	0.79	0.78				0.78	0.70		0.78	0.64	0.6	0.5	0.6	0.7	0.5	0.3		7.03	7.03		7.00	7.00		6.94	0.5	0.5		0.5	0.5		0.00	0.00		0.00	0.00				
28	火	25.0	25.0		25.0	25.2	0.78	0.80				0.76	0.66		0.77	0.65	0.6	0.6	0.6	0.7	0.5	0.3		7.00	6.99		7.00	7.03		6.94	0.5	0.5		0.5	0.4		0.00	0.00		0.00	0.00				
29	水	25.0	25.0		25.0	25.5	0.80	0.81				0.76	0.67		0.76	0.61	0.6	0.5	0.6	0.7	0.5	0.3		6.98	6.96		6.92	6.95		6.95	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
30	木	24.2	24.8		24.2	25.0	0.80	0.81				0.79	0.67		0.76	0.64	0.6	0.5	0.6	0.7	0.5	0.3		6.99	6.98		7.00	7.02		6.89	0.4	0.4		0.4	0.4		0.00	0.00		0.00	0.00				
31	金	24.8	25.0		24.8	25.0	0.78	0.74				0.79	0.66		0.77	0.60	0.6	0.6	0.6	0.7	0.6	0.3		6.95	6.91		6.94	6.92		6.90	0.4	0.4		0.5	0.5		0.00	0.00		0.00	0.00				
合計		—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
平均		23.8	23.9	24.2	23.8	24.0	0.80	0.80				0.70	0.80	0.70		0.80	0.60	0.6	0.5	0.6	0.7	0.5	0.3		7.00	7.00		7.10	7.00	7.00		7.00	0.4	0.4	0.8	0.4	0.4		0.00	0.00	0.00	0.00	0.00		
最大		25.0	25.0	25.0	25.1	25.5	0.87	0.85				0.70	0.81	0.73		0.81	0.69	0.6	0.6	0.6	0.7	0.6	0.3		7.03	7.07		7.19	7.09	7.10		7.17	0.5	0.5	0.8	0.5	0.5		0.00	0.00	0.00	0.00	0.00		
最小		22.2	22.4	23.5	22.2	22.4	0.71	0.71				0.65	0.72	0.65		0.67	0.56	0.5	0.5	0.5	0.6	0.5	0.3		6.95	6.91		7.05	6.92	6.92		6.89	0.3	0.3	0.6	0.3	0.3		0.00	0.00	0.00				

令和2年度4月分 毎日水質検査集計表

(単位mg/L)

日	曜日	水温					残留塩素								NaClO 60%	pH値							色度					濁度														
		大阪水		高地区系	配水B	配水塔	高庄	大阪水		処理水			高地区系	配水B		配水塔	高庄	取石分岐	泉北土牛	千代田	羽衣	東羽衣	綾園	取石	高砂3	大阪水	取石分岐	高地区系	配水B	配水塔	高庄	泉北土牛	大阪水	高地区系	配水B	配水塔	高庄	大阪水	高地区系	配水B	配水塔	高庄
		綾井	北					綾井	北	綾南	綾東	北																														
		綾井	北					綾井	北	綾井	北																															
1	水	13.9	14.0	13.5	13.8	14.0	0.80	0.81				0.72	0.75	0.71	0.80	0.62	0.6	0.6	0.5	0.6	0.6	0.3	7.04	7.06		7.29	7.12	7.05		7.45	0.3	0.3	0.7	0.4	0.4	0.00	0.00	0.00	0.00	0.00		
2	木	13.0	13.0	13.0	12.5	12.5	0.74	0.73				0.75	0.78	0.75	0.80	0.68	0.6	0.6	0.5	0.6	0.6	0.3	7.02	7.03		7.31	7.05	7.03		7.43	0.3	0.3	0.7	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
3	金	13.0	13.4	13.2	13.2	13.0	0.78	0.79				0.73	0.77	0.74	0.80	0.65	0.6	0.6	0.5	0.6	0.6	0.3	7.02	7.03		7.25	7.04	7.05		7.45	0.2	0.2	0.7	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
4	土	13.4	13.9	13.4	13.4	13.6	0.81	0.80				0.74	0.76	0.75	0.80	0.64	0.6	0.6	0.6	0.5	0.6	0.3	7.01	7.00		7.34	7.05	7.05		7.45	0.2	0.2	0.7	0.3	0.2	0.00	0.00	0.00	0.00	0.00		
5	日	13.5	14.0	14.0	13.5	13.5	0.73	0.74				0.75	0.76	0.73	0.81	0.65	0.6	0.6	0.6	0.6	0.6	0.3	7.06	7.04		7.27	7.10	7.14		7.42	0.3	0.3	0.8	0.5	0.3	0.00	0.00	0.00	0.00	0.00		
6	月	12.8	13.2	13.0	13.0	13.5	0.81	0.80				0.72	0.80	0.76	0.81	0.61	0.6	0.6	0.5	0.6	0.6	0.3	7.01	7.01		7.30	7.04	7.06		7.46	0.2	0.2	0.7	0.2	0.2	0.00	0.00	0.00	0.00	0.00		
7	火	13.0	13.2	13.0	13.2	13.2	0.76	0.77				0.80	0.81	0.76	0.80	0.68	0.6	0.6	0.5	0.6	0.6	0.3	7.05	7.06		7.20	7.04	7.02		7.49	0.3	0.3	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
8	水	13.0	13.5	13.2	13.1	13.2	0.78	0.79				0.72	0.78	0.74	0.81	0.61	0.6	0.6	0.5	0.7	0.6	0.3	7.02	7.00		7.26	7.01	7.01		7.52	0.3	0.3	0.7	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
9	木	14.0	14.5	14.0	14.0	14.5	0.77	0.78				0.72	0.79	0.73	0.80	0.61	0.6	0.6	0.6	0.6	0.6	0.3	7.07	7.06		7.36	7.14	7.10		7.54	0.4	0.4	0.8	0.4	0.4	0.00	0.00	0.00	0.00	0.00		
10	金	14.0	14.5	14.4	14.1	14.5	0.82	0.83				0.75	0.80	0.74	0.80	0.65	0.6	0.6	0.6	0.6	0.6	0.3	7.01	7.02		7.42	7.02	7.03		7.51	0.3	0.3	0.7	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
11	土	13.5	14.0	13.5	14.0	14.0	0.73	0.73				0.75	0.79	0.73	0.81	0.65	0.6	0.6	0.6	0.6	0.6	0.3	7.03	7.03		7.34	7.04	7.03		7.51	0.4	0.4	0.7	0.4	0.4	0.00	0.00	0.00	0.00	0.00		
12	日	14.0	14.4	14.5	14.5	14.0	0.80	0.79				0.72	0.73	0.70	0.79	0.65	0.6	0.7	0.5	0.7	0.6	0.3	7.00	7.03		7.20	7.05	7.08		7.47	0.3	0.3	0.6	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
13	月	13.8	13.8	13.0	13.8	13.5	0.80	0.84				0.76	0.78	0.75	0.79	0.66	0.6	0.6	0.5	0.7	0.6	0.3	7.01	7.08		7.19	7.07	7.09		7.52	0.4	0.4	0.7	0.4	0.4	0.00	0.00	0.00	0.00	0.00		
14	火	13.9	14.4	13.5	14.2	13.7	0.83	0.82				0.74	0.78	0.74	0.78	0.66	0.6	0.6	0.6	0.5	0.6	0.3	7.04	7.05		7.32	7.08	7.05		7.55	0.4	0.4	0.8	0.4	0.4	0.00	0.00	0.00	0.00	0.00		
15	水	14.0	14.5	14.0	14.0	14.5	0.79	0.80				0.76	0.77	0.74	0.79	0.65	0.6	0.6	0.6	0.5	0.6	0.3	7.02	7.03		7.26	7.10	7.14		7.55	0.4	0.4	0.8	0.5	0.5	0.00	0.00	0.00	0.00	0.00		
16	木	13.0	14.0	13.2	13.0	14.0	0.83	0.82				0.71	0.80	0.75	0.80	0.61	0.5	0.6	0.6	0.6	0.6	0.3	7.03	7.04		7.30	7.05	7.06		7.56	0.3	0.3	0.7	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
17	金	13.5	13.8	14.0	13.8	14.5	0.81	0.79				0.75	0.77	0.71	0.79	0.66	0.6	0.6	0.5	0.5	0.6	0.3	7.01	7.02		7.30	7.03	7.02		7.58	0.2	0.2	0.7	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
18	土	13.5	13.5	13.5	13.5	14.0	0.72	0.72				0.74	0.77	0.73	0.79	0.61	0.6	0.7	0.6	0.7	0.6	0.3	7.04	7.02		7.34	7.04	7.04		7.53	0.3	0.3	0.7	0.4	0.4	0.00	0.00	0.00	0.00	0.00		
19	日	14.0	14.0	14.5	14.4	14.0	0.79	0.80				0.74	0.73	0.72	0.80	0.65	0.6	0.6	0.6	0.7	0.6	0.3	7.01	7.03		7.30	7.05	7.08		7.51	0.2	0.2	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
20	月	14.0	14.2	14.5	14.0	14.5	0.81	0.80				0.76	0.79	0.74	0.80	0.66	0.6	0.6	0.6	0.7	0.6	0.3	7.02	7.01		7.25	7.03	7.04		7.50	0.2	0.2	0.6	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
21	火	14.0	14.2	14.2	14.0	14.1	0.77	0.75				0.75	0.77	0.72	0.80	0.66	0.6	0.7	0.6	0.5	0.6	0.3	7.02	7.00		7.26	7.02	7.00		7.51	0.2	0.2	0.6	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
22	水	14.5	14.9	14.9	14.8	14.4	0.82	0.83				0.76	0.76	0.77	0.80	0.64	0.6	0.6	0.5	0.7	0.6	0.3	7.03	7.04		7.35	7.06	7.07		7.53	0.2	0.2	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
23	木	14.0	14.8	14.2	14.2	14.2	0.82	0.83				0.76	0.81	0.79	0.78	0.61	0.6	0.7	0.6	0.6	0.6	0.3	7.01	7.02		7.29	7.04	7.05		7.56	0.3	0.3	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
24	金	14.0	14.0	14.2	14.2	14.0	0.76	0.78				0.74	0.75	0.74	0.78	0.60	0.6	0.6	0.6	0.6	0.6	0.3	6.97	7.00		7.19	7.01	6.99		7.52	0.3	0.3	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
25	土	13.9	14.4	14.3	14.1	14.0	0.77	0.80				0.72	0.74	0.74	0.78	0.64	0.6	0.6	0.6	0.7	0.6	0.3	7.03	7.00		7.34	7.11	7.02		7.50	0.3	0.3	0.8	0.5	0.3	0.00	0.00	0.00	0.00	0.00		
26	日	14.5	15.0	15.2	15.0	15.2	0.84	0.83				0.75	0.76	0.74	0.78	0.66	0.6	0.6	0.6	0.5	0.6	0.3	7.02	7.04		7.35	7.05	7.06		7.46	0.2	0.3	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
27	月	14.5	14.5	15.0	15.0	15.0	0.71	0.71				0.74	0.77	0.74	0.78	0.65	0.5	0.7	0.5	0.5	0.6	0.3	7.01	7.02		7.36	7.03	7.03		7.46	0.2	0.2	0.6	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
28	火	14.2	15.0	15.0	14.2	15.0	0.82	0.82				0.75	0.81	0.78	0.78	0.62	0.6	0.7	0.6	0.5	0.6	0.3	7.03	7.04		7.31	7.04	7.05		7.49	0.3	0.2	0.7	0.3	0.2	0.00	0.00	0.00	0.00	0.00		
29	水	14.1	14.9	15.1	14.3	14.8	0.76	0.75				0.70	0.75	0.73	0.78	0.62	0.5	0.6	0.6	0.6	0.6	0.3	7.04	7.00		7.29	7.06	7.04		7.53	0.3	0.2	0.8	0.3	0.3	0.00	0.00	0.00	0.00	0.00		
30	木	15.0	14.8	15.0	15.0	14.8	0.76	0.78				0.71	0.78	0.72	0.78	0.64	0.6	0.6	0.6	0.6	0.6	0.3	7.04	7.03		7.19	7.04	7.07		7.51	0.3	0.3	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
合計		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
平均		13.8	14.1	14.0	13.9	14.1	0.78	0.79				0.74	0.77	0.74	0.79	0.64	0.6	0.6	0.6	0.6	0.6	0.3	7.02	7.03		7.29	7.05	7.05		7.50	0.3	0.3	0.7	0.4	0.3	0.00	0.00	0.00	0.00	0.00		
最大		15.0	15.0	15.2	15.0	15.2	0.84	0.84				0.80	0.81	0.79	0.81	0.68	0.6	0.7	0.6	0.7	0.6	0.3	7.07	7.08		7.42	7.14	7.14		7.58	0.4	0.4	0.8	0.5	0.5	0.00	0.00	0.00	0.00	0.00		
最小		12.8	13.0	13.0	12.5	12.5	0.71	0.71				0.70	0.73	0.70	0.78	0.60	0.5	0.6	0.5	0.5	0.6	0.3	6.97	7.00		7.19	7.01	6.99		7.42	0.2	0.2	0.6	0.2	0.2	0.00	0.00	0.00	0.00	0.00		
備考		2/27~3/2 高地区配水設備更新工事の為、高地区系直送停止																																								